



JOHN KARELL Jr., P.E., M.S.  
Public Health Director

## DEPARTMENT OF HEALTH

Division Of Environmental Health Services

110 Old Route Six Center, Carmel, New York 10512  
(914) 225-0310

June 19, 1991

CERTIFIED RETURN RECEIPT REQUESTED

Michael Barile  
Thomas Boniello  
RD #2, Box 234  
West Lake Boulevard  
Mahopac, New York 10541

Please refer correspondence to:

Name: Lisa Seymour  
Title: Environmental Health Technician  
Phone: (914) 225-0310

### OFFICIAL NOTICE OF NON-COMPLIANCE

You are hereby notified that inspection of the Mahopac Beach and Restaurant, Tax Map #75.43-1-22 by representatives of this Department indicated violations of the Putnam County and New York State Sanitary Code as follows:

1. Article III, Section 4 of the Putnam County Sanitary Code consisting of a discharge of sewage onto the surface of the ground on May 13, 1991.

Approval of proposed repairs must be obtained from this Department prior to any alteration or rebuilding of existing disposal systems. An application is enclosed.

Until such time as repairs are made to the sewage disposal system, the system must be pumped as often as necessary to prevent a discharge to the surface of the ground or Lake Mahopac.

2. Part 14-1.130 NYS Sanitary Code - Sewage Disposal System of portable toilets is not acceptable to the permit issuing official and must be removed immediately.


3. Part 14-1.143 (b)

The handwashing facility located in the bathrooms are not provided with hot and cold running potable water.

Failure to correct these areas of non-compliance by July 3, 1991 will make you liable for additional penalties provided by law, including prosecution on a charge of committing a violation punishable by a fine or imprisonment, or both such fine and imprisonment, as prescribed by law, in addition to such other action as may be prescribed. A reinspection will be made.


It is sincerely hoped that the above-mentioned further action will not be necessary and that you will cooperate by securing the correction of this condition.

For the Public Health Director



John Karell, Jr., P.E.  
Public Health Director

By:



Lisa Seymour  
Sr. Environmental Health Technician

LS:pt

Enc. Permit Application

cc: Phil Miraglia

(T) Building Inspector